

State of Wisconsin \ DEPARTMENT OF NATURAL RESOURCES

Jim Doyle, Governor
Scott Hassett, Secretary
Gloria L. McCutcheon, Regional Director

Southeast Region Headquarters
2300 N. Dr. Martin Luther King, Jr. Drive
Milwaukee, Wisconsin 53212-3128
FAX 414-263-8606
Telephone 414-263-8500
TTY Access via relay - 711

March 21, 2006

MR DENNIS R SAARI PE
EARTH TECH INC
200 INDIANA AVE
STEVENS POINT WI 54481

Project # W-2006-0064
DNR Region: SE
County: WAUKESHA
PWSID # 26846424

SUBJECT: PROPOSED CITY OF DELAFIELD WELL NO. 2

Dear Mr. Saari:

Enclosed is a copy of a letter of approval for the construction of Well No. 2 in the City of Delafield, Wisconsin. We are requesting that you inform us of the date that construction will start, the date that the well will be grouted, the casing thickness and manufacturer's markings, the name of the resident project representative, the proposed grouting method, the proposed method for checking the grout density, the annular space volume, the volume of grout to be ordered, and the proposed test pumping date. This information should be provided to Thanintr Ratarasarn of the Department's Waukesha Service Center, telephone number 262-574-2134, telefax number 262-574-2117. The grouting notice must be given at least 48 hours in advance.

In order to prepare an accurate log for the formations encountered while drilling the well, drill cuttings taken every five feet and at each change in formation must be submitted to the State Geological and Natural History Survey.


In order to conduct a vulnerability assessment, and evaluate the possibility of obtaining monitoring waivers, a Public Water Supply Contamination Source Inventory (Form 3300-215) must be completed and returned to this office. If the inventory form is not completed and submitted to the Department, the well will not be eligible for monitoring waivers.

Also, in addition to collecting two samples of water taken at least 8 hours apart for bacteriological analysis, analyses must be conducted for each of the parameters listed on the enclosed lab forms. The bottles for these samples should be obtained from a Safe Drinking Water Act (SDWA) certified laboratory. The laboratory must be SDWA certified to conduct analyses for each of the parameters indicated on the enclosed lab forms with the exception of the radionuclides. Laboratories performing radionuclide analyses must be certified by the U.S. EPA. The only Wisconsin laboratory certified by the U.S. EPA for radionuclide analyses is the State Laboratory of Hygiene (SLOH). Please contact Mr. Dave Schleis (608/224-6227) of the SLOH for radionuclide analysis information.

In order to collect valid radon gas and organic water samples it will be necessary to provide a method to throttle the test pump discharge and to provide a sample faucet on the test pump discharge piping.

Completed copies of the attached forms must be forwarded to this office along with the specifications for the well pump.

Sincerely,

A handwritten signature in black ink, appearing to read "Francis G. Fuja". The signature is written in a cursive style with a large initial "F".

Francis G. Fuja, P.E.
DG Plan Review Engineer

Enclosures: Bacteriological Lab Form
 Inorganics Lab Form
 Radionuclides Lab Form
 VOC's Lab Form
 SOC's Lab Form
 DNR Form 3300-215

cc: Tom Hafner – City of Delafield DPW, 500 Genesee St., Delafield, WI 53018
 Thanintr Ratarasarn – SER Waukesha
 Lee Boushon – DG/2
 Fuja – DG Reviewer at SER Milwaukee
 USGS
 WG&NHS